

## First Aid & Emergency Eyewashes

**Audited by:**

**Date:**

<u>Item #</u>	<u>Repair Date</u>
---------------	--------------------

**Comments:**

- [illegible]

- ☐ ☐ 4. Where the eyes or body of any person may be exposed to injurious corrosive materials, are suitable facilities for quick drenching or flushing of the eyes and body provided within the work area for immediate emergency use? 1910.151(c)
- ☐ ☐ 5. Can eyewash/shower units be reached within ten seconds? ANSI Z358.1
- ☐ ☐ 6. Where the hazard involves strong acids or caustics, does the employer make sure that eyewash/shower units are immediately adjacent to the hazard? ANSI Z358.1
- ☐ ☐ 7. Is the temperature of flushing fluid lukewarm? ANSI Z358.1
- ☐ ☐ 8. Is eyewash/shower unit unobstructed? ANSI Z358.1
- ☐ ☐ 9. Are plumbed emergency eyewash stations and showers activated weekly and inspected annually? ANSI Z358.1

**Notes:**