

Fixed Industrial Stairs

Audited by:

Date:

<u>Item #</u>	<u>Repair Date</u>
---------------	--------------------

Y N

- ☐ ☐ 11. Are standard railings provided on the open sides of all exposed stairways and stair platforms? 1910.24(h)
- ☐ ☐ 12. Are handrails provided on at least one side of closed stairways preferably on the right side descending? 1910.24(h)
- ☐ ☐ 13. Is the vertical clearance above any stair tread to an overhead obstruction at least 7 feet measured from the leading edge of the tread? 1910.24(i)

[illegible]
